

East Lake Sammamish Trail Segment 2B SSDP2016-00415 - PUBLIC WORKS COMMENTS

I. Civil Engineering Drawings		
Item/Topic	City of Sammamish Comments	King County Responses
General		
1	Provide temporary erosion and sediment control plans in conjunction with Section 25.06.050 of the City of Sammamish Municipal Code. These plans should clearly show the following items:	TESC Plans were submitted with the permit application and are also included in the revised 60-percent plans. Please note that provision of TESC plans is not a requirement for shoreline permit review.
a	Trees to be removed and retained.	A separate set of tree preservation plans has been submitted in support of shoreline permit review. Information regarding tree removal and retention will be added to the Site Preparation Plans in the 90-percent plans.
b	Existing culverts to be removed.	New or modified culverts are shown on the AL sheets. Culverts to be removed will be shown on the Site Preparation sheets in the 90-percent plans.
c	Physical features located within the trail right-of-way to be removed as part of the construction. Many of the existing stairs are called out to be removed, but there are several that don't have any type of designation.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
d	The standard best management practices required typically shown in TESC plans.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
2	There are several driveways proposed to be removed as part of the trail construction. Provide an overall schematic plan showing preconstruction access, access during construction, and post construction access. Clearly demonstrate how each of the residences will be accessing their homes based on the construction. Also demonstrate that proposed driveway revisions do not impact existing emergency vehicle access and turn arounds. Once plan is provided, City will route to Fire Department for comment. Since adding additional trips to existing driveways, sight distance analysis at ELSP will be required for each affected driveway.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
3	Show all existing utilities to remain that cross the trail in the profiles. There are several culverts to remain that need to be shown.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
4	Provide cross sections of the trail every 100 feet. These sections do not have to be included in the formal plan set, but can be provided as a separate submittal for general reference. It is difficult to determine the boundary conditions of the proposed trail based on the current information provided and the cross sections would aid significantly in the review.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
5	Clearly demonstrate that the properties downstream of the infiltration facilities and the dispersion areas won't be negatively impacted (see TIR comments).	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
General (continued)		
6	Indicate jetting, cleaning, and TV of all existing storm pipe and culverts to be retained in system.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
7	Indicate jetting, cleaning, and TV of all new storm pipe, culverts, and underdrains in system.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
8	Show right-of-way dedication adjacent to ELSP (minor arterial) consistent with dedication requirements in accordance to vested Public Works Standards. City will have a peer review surveyor review ROW dedication.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
9	For all stairs to be removed, clearly show extent of removal. For example, will only the part of stairs within the clearing limits be removed. This could provide some safety issues. How will removed stair areas be restored?	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
Existing Condition Plans		
10	The existing and proposed contours are too light and difficult to see in the plans provided (half-size). Show the contours darker on these plans for clarity.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
11	The ROW shown in the plans doesn't match King County Assessor's information and the property owner's information at Stations 453+00 and 457+00. Verify the limits of the ROW and update the plans accordingly.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
12	Public Comment indicates a significant dogwood at Station 295. Please verify and show on plans.	A qualified arborist inventoried significant trees within the corridor (see Tab 11). A significant dogwood was not identified in this area.
13	Public Comment indicates that Jurisdictional Ditch #11A from Station 319 to Station 322 flows to south. Please verify and show on plans.	Detailed observations and comments were provided in the Watershed Company's report for the City. As noted in King County's respnses to these comments, some revisions are appropriate regarding the flow in this ditch. Please refer to Tab 2, Table 1 for these dedtails.
14	Public Comment indicates a row of arborvitae on east side of house at 2417 E Lake Sammamish Place near Station 326 and 327. Please verify and show on plans.	A qualified arborist documented the presence of this hedge in an inventory report (Tab 11). King County is not required to show every plant and hedge on the construction documents unless the trees are significant.
15	Public Comment indicates significant ponding in Jurisdiction Ditch #11B with no outlet. Please verify outlets of four 6-inch PVC culverts as shown on plans at Station 327.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
16	Public Comment indicates power runs to lights on existing rockery to be replaced at Station 371+50. Please show on plans and protect as needed.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
17	Public Comment indicates 36-inch concrete pipe at approximate Station 386+50 discharges to a 20-ft tank before outletting to Lake Sammamish. Please contact property owner to verify and add leader to plans. Add discussion in TIR.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
Existing Condition Plans (continued)		
18	Locate and show on plans inlet to 12-inch CMP to CB P#25644 at approximate Station 386+50.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
19	Public comment indicates at 3145 E Lake Sammamish Shore Lane SE near Station 294 and Station 295, there is a heritage dogwood. Please verify and show on plans. Show protection on AL Sheets as appropriate.	Please see response to Comment #13.
Typical Cross Sections		
20	Provide a typical cross section for the trail with the underdrain trench adjacent to a structural earth wall.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
Sheet AL1 - Plan and Profile		
21	Address how runoff from the slope down from East Lake Sammamish Parkway SE will be collected and conveyed across the trail between Station 284+00 to 287+50.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
Sheet AL2 - Plan and Profile		
22	Provide an infiltration test at the location of the proposed infiltration facility.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
23	Provide emergency overflow from the proposed infiltration facility and that demonstrate that this facility won't adversely impact the downstream property (private park).	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
Sheet AL3 - Plan and Profile		
24	Public Comment questions the need to remove fence from Station 294 to Station 295. Please review and revise CG if feasible.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
Sheet AL4 - Plan and Profile		
25	Provide a detail for the gravity block wall with fencing.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
26	Demonstrate how sheet flow from the trail won't negatively impact the adjacent downstream homes (Station 300+00 to 301+00).	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
Sheet AL5 - Plan and Profile		
27	Adjust the stationing in the profile to match the plan.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL6 - Plan and Profile		
28	Address what happens to the drainage at the low point at Station 308+00. The trail slopes towards the wall and is not collected in any type of conveyance system.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
29	Demonstrate that the trail from Station 308+50 to 311+00 that sheet flows to the east won't negatively impact the adjacent homes.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
30	Public Comment requests relocation of Type 1 Rest Area to Station 306+50. Please address the siting of the rest in the proposed location.	The location is within the County-owned corridor, outside critical areas and buffers, and outside the 50-foot shoreline setback area. No change is proposed.
31	Public Comment questions need to replace existing ramp with Stair #14. Please address and revise if feasible.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
32	Public comment indicates there are underground utilities serving cabin at 2917 and 2905 E Lake Sammamish Parkway SE. Please show on plans and protect.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL8 - Plan and Profile		
33	Specify plan for existing rockery at approximate Station 319.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
34	Public Comments asserts that home at 2609 East Lake Sammamish Shore Ln SE is the low point in the neighborhood and receives both surface and groundwater. Please investigate and verify that drainage conditions will be unaffected or improved.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL9 - Plan and Profile		
35	Public Comment indicates erosion and slide concerns over slope cuts/fills from Station 320+50 to Station 324. Please address on plans and Geotechnical Report.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL10 - Plan and Profile		
36	Address the plan for the drainage on the east side of the trail from Station 325+00 to 327+00. Where does it outlet and/or get to the other side of the trail?	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
37	Place CB #9 at the low point in the trail (Station 327+16) as shown in the profile.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
38	Public Comment indicates that Jurisdictional Ditch #11B has standing water with no outlet. Please address and provide outlet for ditch to CB #9 if feasible.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
39	Public Comment suggests shift of trail alignment at Station 324 to 324+50 instead of Station 327. Please provide reasoning on the proposed trail shift location.	The trail alignment considers proximity to critical areas, drainage, topography, and geometry of intersections with driveways. No change in alignment is proposed.
40	Public Comment indicates underground power under trail near Station 329. Please show and address.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
41	Clearly show if Stair 34 and unidentified stairs at Station 329 are to be retained, modified, or removed.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL11- Plan and Profile		
42	Public Comment indicates underground power under trail near Station 332+25. Please show and address.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
43	Address wood bridges and how they will be affected by work.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
44	Clearly show if Stair 37, 38, 39, and 40 are to be retained, modified, or removed. Unclear how transition will be safely made if only removing to clearing limits.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL13 - Plan and Profile		
45	Provide a detail for the rock-lined ditch located to the west of Outfall #3.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
46	Identify extent of existing storm at CB 7055.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL 14 - Plan and Profile		
47	Address the plan for the drainage between Station 347+50 to 351+00. It currently sheets flows westward toward the retaining wall.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
48	Public Comment indicates there is a sprinkler system near Stair 47. Please address.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
49	Address impact to retaining wall at Station 348+90 where clearing limits jog around wall.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL15 - Plan and Profile		
50	Public Comment indicates water and power lines to the wood shed at Station 351+70. Public comment indicates wood shed is a pump house and location is incorrectly shown on plans. Please verify, show, and address underground utilities.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL16 - Plan and Profile		
51	Provide infiltration testing for the proposed infiltration trench in accordance with the King County Surface Water Design Manual requirements. The trench is being proposed at a location where there are currently wetlands and standing water adjacent to the trail.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL17 - Plan and Profile		
52	Unclear where CB 16 discharges. Please clarify on plans.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL18 - Plan and Profile		
53	The existing pipe upstream of the pipe into CB #17 is 36-inches in diameter. Verify that the capacity of the proposed 12-inch pipe out of CB #17 is sufficient.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
54	Public Comment indicates that Tom Hornish owns property at 1237 East Lake Sammamish Shore Ln SE. Please verify and correct.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL19 - Plan and Profile		
55	Provide infiltration testing for the proposed infiltration trench in accordance with the King County Surface Water Design Manual requirements. The trench is being proposed at a location where there are currently wetlands and standing water adjacent to the trail. Trail low point appears to be at Station 370+25. Assess any overtopping of Driveway 9.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
56	Public Comment indicates boat house and dock not shown at 1204 E Lake Sammamish Parkway SE.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL21 - Plan and Profile		
57	The proposed 24-inch diameter culvert at Station 384+23 discharges to an existing 12-inch culvert further downstream. Verify that there won't be any adverse impacts to the downstream property and that the 12-inch culvert can accommodate drainage from the upstream basin modelled as fully developed.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL22 - Plan and Profile		
58	Demonstrate that the dispersion area is designed in accordance with KCSWDM requirements for basic dispersion. This includes the following:	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
a	The flowpath segment must be over well-established lawn or pasture, landscaping with well-established groundcover, or native vegetation with natural groundcover. The groundcover must be dense enough to help disperse and infiltrate flows and to prevent erosion.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
b	That the slope of the flowpath segment must be no steeper than 15% for any 20-foot reach of the flowpath segment. The grading is currently shown at 33%.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
c	Sheet flow shall include crushed rock edge line.	

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL23 - Plan and Profile		
59	Trees shown at Station 393+50 to 394+25 shall be shown as protected if feasible.	There are over 800 significant trees that have been inventoried in the corridor. Where feasible, trees are already shown as saved or monitor. Based on avoidance and minimization efforts already implemented, over 500 will be saved.
AL24 - Plan and Profile		
60	The fill on the east side of the trail from Station 395+00 to 400+00 will create a natural ditch section. Address the drainage plan for this area.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
61	Provide infiltration testing for the proposed infiltration trench in accordance with the King County Surface Water Design Manual requirements.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL25 - Plan and Profile		
62	Verify that the proposed grading in the dispersion area meets the KCSWDM slope criteria and vegetation cover requirements	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL26 - Plan and Profile		
63	Show the proposed grading for the new driveways (spot elevations and contours).	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL28 - Plan and Profile		
64	The dispersion area from Station 417+00 to 419+00 is shown in cut. Verify that the dispersion area slopes away from the trail.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
65	Verify of clearing limits need to extend to garden area at Station 419+25.	To the extent that this comment is about preserving a garden, this is not a shoreline comment. King County uses criteria in the Washington State Department of Transportation Construction Manual to establish clearing and grubbing limits. Specifically, Chapter 2 Section SS 2-01.3(1) Clearing states: "Where slope treatment is provided clearing should normally be staked to a distance of 10 feet beyond the limits of the slope treatment with a distance of 5 feet being considered the absolute minimum distance required." Section SS 2-01.3(2) Grubbing states: "The clearing and grubbing limits shall be 5 feet beyond the toe of a fill and 10 feet beyond the top of a cut unless otherwise shown in the Plans." In many areas, King County is proposing the use of retaining walls to reduce the limits of cuts and fills. Where retaining walls are proposed to minimize trail footprint, the clearing and grubbing limits are typically shown at 10 feet beyond the base of a fill wall and top of a cut wall.
AL29 - Plan and Profile		
66	Verify that the proposed grading in the dispersion area meets the KCSWDM slope criteria and vegetation cover requirements.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
67	Verify that new fence is needed.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL29 - Plan and Profile (continued)		
68	Significant trees shown should be retained as part of dispersion if feasible.	There are over 800 significant trees that have been inventoried in the corridor. Wheree feasible, trees are already shown as saved or monitor. Based on avoidance and minimization efforts already implemented, over 500 will be saved.
69	Update Zackuse culvert and channel consistent with coordination with City Zackuse Creek Fish Passage and Stream Restoration project.	King County has been and will continue to coordinate with the City of Sammamish regarding the replacement of culverts along Zackuse Creek. The Revised 60-percent Plans have been updated to reflect this coordination.
AL30 - Plan and Profile		
70	Verify that new fence is needed.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
71	Significant trees shown should be retained as part of dispersion if feasible.	There are over 800 significant trees that have been inventoried in the corridor. Wheree feasible, trees are already shown as saved or monitor. Based on avoidance and minimization efforts already implemented, over 500 will be saved.
AL31 - Plan and Profile		
72	Provide a detailed plan for the walkway. Show landings in plan view and the ADA handrail. Show revisions to the guardrail at the top of the ramp necessary for access.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL32 - Plan and Profile		
73	Provide a culvert underneath the proposed driveway at Station 438+44 to accommodate the flows from Jurisdictional Ditch #17.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL33 - Plan and Profile		
74	Provide infiltration testing for the proposed infiltration trench in accordance with the King County Surface Water Design Manual requirements.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
AL34 - Plan and Profile		
75	Public Comment for 813 ELSP NE indicates a desire to keep existing fence. Verify need to remove and adjust plans as appropriate.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.
AL35 - Plan and Profile		
76	Provide a detailed plan of the proposed parking area and additional details about the design of the wall and wall heights.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
AL36 - Plan and Profile		
77	Public Comment at 1111 ELSP NE indicates that fence and covered entrance are within CG limits. Please verify and adjust CG as appropriate.	Not a shoreline comment: This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately respond to such comments received as part of the SSDP review process that are outside the scope of this permit application in the summer or fall of 2017.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
AL37 - Plan and Profile		
78	Provide infiltration testing for the proposed infiltration trench in accordance with the King County Surface Water Design Manual requirements.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
79	Have the geotechnical engineer verify that it is feasible and advisable to provide an infiltration trench at the top of the retaining wall. Provide a section of the wall at this location with additional details. Include recommendation in Geotechnical Report.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
SD1 - Storm Drainage Profiles and Sections		
80	Provide steel casings for the storm pipes through or underneath the retaining walls.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
81	Provide a rip rap pad for the outlet of the 24" culvert for Profile 384+25.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
SD2 - Storm Drainage Profiles and Sections		
82	Provide inlet protection for the pipes.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
83	Show the existing ground profile for both profiles.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
Fish Passage Culverts		
84	Provide approvals from the Washington Department of Fish and Wildlife for the design of each of the fish passage culverts.	King County is reviewing and responding to shoreline comments prior to submitting a Joint Aquatic Resource Permit Application to Washington Department of Fish and Wildlife (WDFW) for Hydraulic Project Approval. That submittal is expected to occur in late summer 2017. When WDFW approves the permit, a copy of the approval will be provided to the City of Sammamish.
85	Coordinate the design and size of the Zackuse Creek fish passage culvert with the City of Sammamish in order to provide consistency between the culvert beneath the trail and the culvert project currently being designed by the City.	King County has been and will continue to coordinate with the City of Sammamish regarding the replacement of culverts along Zackuse Creek. The Revised 60-percent Plans have been updated to reflect this coordination.
Driveway Plan and Profile Sheets		
86	Provide spot elevations and proposed contours for each of the driveways. There are several situations where the trail cross slope is opposite of the driveway slope. Show appropriate cross slope transition areas.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
87	Verify that the grades shown in the driveway profiles matches the proposed cross slope of the trail.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
88	For the driveways to be removed, show removal of the existing asphalt pavement up to the edge of the existing roadway. Currently the removal stops at the edge of the trail ROW which would leave an unnecessary remnant of asphalt pavement.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.

I. Civil Engineering Drawings (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
Driveway Plan and Profile Sheets (continued)		
89	For the driveways proposed to be removed, provide support from East Side Fire and Rescue that the homes can still be accessed for emergency purposes.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
Wall Profiles		
90	Provide structural details and typical cross sections for each of the wall types called out in the plans (rockery, structural earth and gravity block walls).	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
91	Show the proposed stairs to be constructed in the wall profiles for reference.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
92	Show the proposed and existing culverts to remain in the wall profiles.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
92	Demonstrate how existing culverts to remain that are located beneath the proposed walls will be protected from the new loads imposed by the walls.	This comment is not relevant to the City's review of the shoreline substantial development permit application as it addresses matters outside the scope of the Shoreline Management Act and the City of Sammamish Shoreline Master Program. The County will separately establish compliance with the requirements related to this comment as part of the relevant permit review.
Landscape Plan		
94	Show the planting proposed for dispersion areas that meets the requirements of the KCSWDM for dispersion located between the following stations:	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
a	400+00 to 402+30	See above.
b	408+30 to 419+00	See above.
c	420+20 to 424+20	See above.
d	426+30 to 431+60	See above.
II. Technical Information Report		
Item/Topic	City of Sammamish Comments	King County Responses
95	Update TIR to address vested Surface Water Design Manual requirements.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
96	There are several culverts missing from Table 5-1 Summary of Existing Culverts and Proposed Action (Station 340+00, 342+75, 432+80, 454+50, etc.). Please check the table and update the status of these culverts accordingly.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
97	For all proposed exemptions to flow control facilities required in accordance with Core Requirement No 3, demonstrate how each TDA meets all criteria. For example, for all direct discharge exemptions, provide documentation that all criteria in the vested Surface Water Design Manual are met.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
98	For each TDA, discuss any new proposed driveways and any new pollution generating impervious surfaces related to Core Requirement No. 8.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.

II. Technical Information Report (continued)		
Item/Topic	City of Sammamish Comments	King County Responses
99	For each TDA, discuss any new pervious and impervious surfaces proposed by the project and how they meet requirements of Core Requirement No 3, 8, and 9.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
100	For each TDA, include analysis of impacts to downstream conditions where any dispersion or infiltration is proposed. Depict through a figure where stormwater will be conveyed in emergency situations and show an overflow path if downstream flooding of driveways and homes would occur.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised TIR, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
III. Geotechnical Report		
101	Update Geotechnical Report to address infiltration testing using the requirements of the vested Surface Water Design Manual.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised Geotechnical Report, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
102	Show results and analysis of infiltration testing as commented throughout Engineering Drawings. Show location of each test pit as it relates to proposed design.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised Geotechnical Report, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.
103	For each TDA proposing infiltration, include analysis of downstream groundwater conditions that could affect homes and private property.	Pursuant to the settlement agreement dated April 6, 2017 between the City of Sammamish and King County, the County is presently updating the drainage design for the trail to meet the most current stormwater regulations. This work will be completed later this year and the updated drainage design, along with a revised Geotechnical Report, will be provided with the 90-percent plans in support of a grading permit application. This comment will be addressed at that time.